



250 W. First Street, Prosper, TX 75078
Phone 972-346-3502

Site Lighting Verification Form

This document must be completed by the design professional of record for this project.
Please submit the completed form through the online portal prior to Building Final Inspection.

Permit Number: _____ Date: _____

Project Name: _____

Project Address: _____

Yes No Site lighting has been installed per the photometric plans and specifications associated with this project.

Yes No The height of the parking lot light poles do not exceed a height of thirty (30) feet.

Yes No The height of the parking lot light poles do not exceed a height of twenty (20) feet when within 100 feet of a *protected residential property*.

Yes No Light reading levels adjacent to the street right-of-way do not exceed 0.50 foot candle.

Yes No Light reading levels along property lines adjacent to *protected residential properties* do not exceed 0.25 foot candle.

Yes No All luminaries located on non-residential use properties shall be designed and installed so the light source (bulb or lamp) is completely shielded from direct view at a point of three (3) feet above grade on the lot line abutting a *protected residential property*.

Yes No All luminaries located on non-residential use properties shall be designed and installed so the light source (bulb or lamp) is completely shielded from direct view at a point of five (5) feet above grade on the lot line abutting other than a *protected residential property*.

Protected Residential Property: Any property within the Town that meets one (1) of the following requirements:

- The property is zoned a residential district as defined within the Zoning Ordinance or zoned a planned development for residential uses;
- The property is designated on the Comprehensive Plan as any type of residential; or,
- The property is used or subdivided for use as residential.

Registered Design Professional: _____

Signature: _____ Seal: _____