



Annual System Maintenance Period Daily Disinfectant Residuals

Friday, March 7, 2025	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
Custer Pump Station	2.16	1.92
920 Jessica Ln	0.84	0.43
4460 Honeyvine Ln	1.44	0.00
5681 Crestwood Dr	1.50	0.00
Craig Street Water Tower	1.18	0.91
Prosper Trail Water Tower	1.41	1.14
Fishtrap Water Tower	1.04	0.00
1341 Kirkwood Ln	1.30	0.00
Main St & First St	0.92	0.56
Technology Way	0.62	0.28
Lakeview Apartments	1.15	0.86
Texas Bank	1.32	1.13
300 W Broadway St	0.88	0.66
202 E 2nd St	0.68	0.45
Church St & 5th St	0.67	0.47